



MAIL TYPE

Workflow Transmittal

MAIL NUMBER

TRS12T09-WTRAN-003011

REFERENCE NUMBER

TRS12T09-WTRAN-003011

Final (WF-000551) R12-T09B02 - [ARCCO] - CMA STREET LIGHTING POLE 6MTR (AL AAMEDAH)

From

Mr Jurgen Kurti - The Red Sea Development Company

To (11)

Mr Mujahid Ahmed Khan - Al Raeel Engineering Construction & Development Co. Ltd. (+10 more...)

Cc (8)

Mr Morsi Fouad - Al Raeel Engineering Construction & Development Co. Ltd. (+7 more...)

Sent

Tuesday, 4 January 2022 5:59:23 PM AST (GMT +03:00)

Status

N/A

DOCUMENT ATTACHMENTS (1)

(0 selected)				
File	Document No	Revision	Title	Status
	R12-T09B02-RCO-MAT-EL-0031	00	CMA STREET LIGHTING POLE 6MTR (AL AAMEDAH)	Accepted with Comments

ATTRIBUTES

Attribute 1

Site Wide

MESSAGE

Workflow Review History

The attached documents have completed the "R12-T09B02 - [ARCCO] - CMA STREET LIGHTING POLE 6MTR (AL AAMEDAH)" workflow with the following results :

This transmittal was automatically generated.

Doc No	Step	Participant	Review Outcome	Comments
R12-T09B02-RCO-MAT-EL-0031	TRSDC Document Controller -Gate Keeper	M Ahmed	Accepted	
	Electrical Manager -	M Taha	Accepted with Comments	1.Street poles locations to

Review

be coordinated +/- with
Landscape layout 2.Light
Shield to be provided from
the light manufacture
3.Final Approval is subject
to installtion,T&C
inspection approvals
4.Approval of submittals
by The Employer/ The
Engineer shall not relieve
The Contractor of its
contractual obligations to
perform and complete the
work in strict accordance
with the contract
documents, project
requirements, relevant
codes & standards, and
Authorities Acceptance
and approval
5.Foundation design to be
submitted for structural
approval

Construction Manager -
Review

M Taha

Accepted with Comments

1.Street poles locations to
be coordinated +/- with
Landscape layout 2.Light
Shield to be provided from
the light manufacture
3.Final Approval is subject
to installtion,T&C
inspection approvals
4.Approval of submittals
by The Employer/ The
Engineer shall not relieve
The Contractor of its
contractual obligations to
perform and complete the
work in strict accordance
with the contract
documents, project
requirements, relevant
codes & standards, and
Authorities Acceptance
and approval
5.Foundation design to be
submitted for structural
approval

Project Manager -Review Z Almujaali

Accepted with Comments

1. All Street Lights to be
provided with glare
shields / cowls. 2. Color

temperature shall be 3000K or less. 3. Dimming Control system to be provided to ensure street lights can be programmed / dimmed / turned off when not in use. 4. Warranties are to be submitted separately for final approval. ARCCO is to provide a close-out sheet to highlight all warranties with duration for each warranty. 5. Warranty duration and initiation is to be as per contractual specification. 6. Refer to review comments.

Project Manager / Director -Approval	J Kurti	Accepted with Comments
---	---------	------------------------